



CAWANGAN KEJURUTERAAN ELEKTRIK
JABATAN KERJA RAYA MALAYSIA

SIJIL EMAL

Sijil Pendaftaran Bahan/Barangan Elektrik (Electrical Material Approved List) ini dikeluarkan kepada **pengilang/pembekal** :

Syarikat : **SIRIJAYA INDUSTRIES SDN. BHD.**

Alamat : NO. 9, LEBUH PERUSAHAAN KLEBANG 9, IGB INTERNATIONAL INDUSTRIAL PARK,
31200 CHEMOR, PERAK DARUL RIDZUAN

Bahan : **FLUORESCENT LUMINAIRES (T5)**

Pendaftaran ini adalah seperti butiran di bawah dan tertakluk kepada Spesifikasi JKR dan **syarat-syarat di muka surat 2**.
Sijil ini hendaklah dibaca bersama **Lampiran** (3 muka surat).

Pengilang	: SIRIJAYA INDUSTRIES SDN. BHD.
Negara Pengilang	: MALAYSIA
Jenama	: SJ LITE
Model	: 1) SSV 214 2) SRV 214 DAN SEPerti LAMPIRAN
Kadaran	: 240V & 50Hz
No. Perakuan ST/No. Sijil/ Laporan Ujian Jenis	: PERAKUAN ST : SGT161312186392022 DAN SEPerti LAMPIRAN PENSIJILAN SIRIM : PS008202 & PS008206 LAPORAN UJIAN SIRIM : 2021PB0008 DAN SEPerti LAMPIRAN
Tarikh Tamat	: 15.06.2026
Rujukan Standard	: MS IEC 60598-1:2012, MS IEC 60598-2-1:1997, MS IEC 60598-2-2:1998 & CIE 121-1996
Catatan	: i) REFLECTOR : MIRO 4 ii) ELECTRONIC BALLAST : SJLITE - AES 1X14-35 IP & AES 2X14-28 IP PHILIPS - HF-S 114-35 TL5 II & HF-S 214-28 TL5 II OSRAM - QT-FIT5 1X14-35 & QT-FIT5 2X14-35 iii) LAMP HOLDER : SIRIJAYA - S532, S533, S960, S961, S910 & S911



Tarikh dikeluarkan/diperbaharui : 17 April 2024

Ir. HANIZAN BINTI SHAFFII

Pengarah Kanan

Cawangan Kejuruteraan Elektrik

b.p Ketua Pengarah Kerja Raya

JKR Malaysia

Ruj.Kami : (29) dlm. JKRL(PM)5/1/4-11 Jld. 16
Tarikh : 17 April 2024

Syarat-syarat Senarai Kelulusan Bahan-Bahan JKR Elektrik.

- 1 Senarai tersebut adalah untuk digunakan oleh Cawangan Kejuruteraan Elektrik JKR sahaja dan tidak boleh digunakan untuk apa jua pengiklanan atau untuk apa jua tujuan lain. Sila hubungi pejabat ini sekiranya terdapat sebarang kemusykilan berkaitan dengan perkara ini.
- 2 Untuk mendapat penyenaraian tambahan ke atas sebarang model, pertukaran, pengubahsuaian dan sebagainya ke atas barangan sedia ada, tuan hendaklah memohon ke pejabat ini secara bertulis berkaitan perkara tersebut. Pejabat ini tidak bertanggungjawab ke atas sebarang kesulitan yang mungkin timbul berpunca daripada kegagalan pihak tuan memenuhi syarat-syarat tersebut.
- 3 Sekiranya tuan ingin kekalkan barangan tuan di dalam senarai JKR, tuan hendaklah memastikan ke semua kelulusan seperti Perakuan Suruhanjaya Tenaga, Lesen Pensijilan SIRIM dan Sijil Kelulusan Jabatan Bomba dan Penyelamat yang mana berkenaan masih belum tamat tempohnya. Tuan hendaklah mengemukakan salinan sijil-sijil yang diperbaharui berserta Borang Akuan yang diperakui oleh Pesuruhjaya Sumpah sepanjang tempoh pendaftaran sebagai syarat untuk mengekalkan barangan berkenaan dalam senarai kelulusan.
- 4 **Cawangan Kejuruteraan Elektrik JKR berhak untuk menarik balik kelulusan pendaftaran sekiranya barangan ini tidak lagi mematuhi standard, spesifikasi, kualiti barangan yang dibekalkan tidak seperti berdaftar, gagal dalam pengujian dan/atau gagal mengemukakan perkara dalam para tiga (3) di atas.**
- 5 Sila ambil perhatian bahawa pihak tuan hendaklah memastikan pembaharuan pendaftaran dibuat **tiga bulan** sebelum tarikh tamat kelulusan ini. Sekiranya pihak tuan gagal berbuat demikian, barangan tuan dengan sendirinya akan terkeluar daripada senarai bahan-bahan kelulusan JKR.

Pihak syarikat bersetuju dengan syarat-syarat tersebut di atas.

Tandatangan:

Tarikh: 23/4/2024

Nama: Liew Kok Weng

Jawatan: Managing Director
(Ahli Lembaga Pengarah)

Cop Syarikat: SIRIJAYA INDUSTRIES SDN. BHD.
(Co. No: 153828-D)
No. 9, Lebuhr Perumahan Klebang 3,
IGB International Industrial Park,
31200 Chemor, Perak.
05-2923888 (Hunting Line) 2912223, 2912222
Fax: 05-2912221, 2912222



LAMPIRAN

Perihal Barangan : FLUORESCENT LUMINAIRES (T5)

Nama Syarikat : SIRIJAYA INDUSTRIES SDN. BHD.

Alamat Syarikat : NO. 9, LEBUH PERUSAHAAN KLEBANG 9, IGB INTERNATIONAL INDUSTRIAL PARK,
31200 CHEMOR, PERAK DARUL RIDZUAN

No. Tel : 05 - 292 3888

No. Fax : 05 - 291 2222

Email : qa@sirijaya.com

Nama Pengilang : SIRIJAYA INDUSTRIES SDN. BHD.

Negara Pengilang : MALAYSIA

Jenama : SJ LITE

No. Perakuan ST/ No. Sijil/ Laporan Ujian Jenis : PERAKUAN ST : SJT161312186392022, SJT161307107342023, SJT161307115272023,
SJT161307115332023, SJT161307117182023, SJT161307117342023, SJT161308119712023,
SJT161308135822023, SJT161308135832023, SJT161308135842023, SJT161308126502023 &
SJT161311189832023
: PENSIJILAN SIRIM : PS008202 & PS008206
: LAPORAN UJIAN SIRIM : 2021PB0008, 2021PB0008-A1, 2021PB0009, 2021PB0009-A1, 2021PB0103,
2021PB0103-A1, 2022PB0093, 2022PB0104, 2022PB0105, 2022PB0107, 2022PB0108, 2022PB0109,
2022PB0110, 2022PB0111 & 2022PB0112
: LAPORAN UJIAN LIGHTLAB : LL18693

Tarikh Tamat : 15.06.2026

Rujukan Standard : MS IEC 60598-1:2012, MS IEC 60598-2-1:1997, MS IEC 60598-2-2:1998 & CIE 121-1996

Catatan : i) REFLECTOR : MIRO 4
ii) ELECTRONIC BALLAST : SJLITE - AES 1X14-35 IP & AES 2X14-28 IP
PHILIPS - HF-S 114-35 TL5 II & HF-S 214-28 TL5 II
OSRAM - QT-FIT5 1X14-35 & QT-FIT5 2X14-35
iii) LAMP HOLDER : SIRIJAYA - S532, S533, S960, S961, S910 & S911

Muka surat : 1 daripada 3

KETERANGAN

BIL	MODEL	KADARAN WATT (W)	LIGHT OUTPUT RATIO (%)	JENIS
1	SSV 214	2 X 14	83.0	Surface Mounted Channel c/w Aluminium Reflector And Louvre
2	SRV 214	2 X 14	83.0	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
3	SRV 214 (1X2)	2 X 14	87.0	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
4	SWV 214	2 X 14	83.0	Recessed Mounted Channel c/w Aluminium Reflector And Louvre
5	SSV 314	3 X 14	91.2	Surface Mounted Channel c/w Aluminium Reflector And Louvre
6	SRV 314	3 X 14	91.2	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
7	SWV 314	3 X 14	91.2	Recessed Mounted Channel c/w Aluminium Reflector And Louvre
8	SSV 414	4 X 14	87.5	Surface Mounted Channel c/w Aluminium Reflector And Louvre
9	SRV 414	4 X 14	87.5	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre



Perihal Barangan : FLUORESCENT LUMINAIRES (T5)

Nama Syarikat : SIRIJAYA INDUSTRIES SDN. BHD.

Alamat Syarikat : NO. 9, LEBUH PERUSAHAAN KLEBANG 9, IGB INTERNATIONAL INDUSTRIAL PARK,
31200 CHEMOR, PERAK DARUL RIDZUAN

No. Tel : 05 - 292 3888

No. Fax : 05 - 291 2222

Email : qa@sirijaya.com

Nama Pengilang : SIRIJAYA INDUSTRIES SDN. BHD.

Negara Pengilang : MALAYSIA

Jenama : SJ LITE

No. Perakuan ST/ No. Sijil/ Laporan Ujian Jenis : PERAKUAN ST : SJT161312186392022, SJT161307107342023, SJT161307115272023,
SJT161307115332023, SJT161307117182023, SJT161307117342023, SJT161308119712023,
SJT161308135822023, SJT161308135832023, SJT161308135842023, SJT161308126502023 &
SJT161311189832023
: PENSIJILAN SIRIM : PS008202 & PS008206
: LAPORAN UJIAN SIRIM : 2021PB0008, 2021PB0008-A1, 2021PB0009, 2021PB0009-A1, 2021PB0103,
2021PB0103-A1, 2022PB0093, 2022PB0104, 2022PB0105, 2022PB0107, 2022PB0108, 2022PB0109,
2022PB0110, 2022PB0111 & 2022PB0112
LAPORAN UJIAN LIGHTLAB : LL18693

Tarikh Tamat : 15.06.2026

Rujukan Standard : MS IEC 60598-1:2012, MS IEC 60598-2-1:1997, MS IEC 60598-2-2:1998 & CIE 121-1996

Catatan : i) REFLECTOR : MIRO 4
ii) ELECTRONIC BALLAST : SJLITE - AES 1X14-35 IP & AES 2X14-28 IP
PHILIPS - HF-S 114-35 TL5 II & HF-S 214-28 TL5 II
OSRAM - QT-FIT5 1X14-35 & QT-FIT5 2X14-35
iii) LAMP HOLDER : SIRIJAYA - S532, S533, S960, S961, S910 & S911

Muka surat : 2 daripada 3

KETERANGAN

BIL	MODEL	KADARAN WATT (W)	LIGHT OUTPUT RATIO (%)	JENIS
10	SWV 414	4 X 14	87.5	Recessed Mounted Channel c/w Aluminium Reflector And Louvre
11	SSV 228	2 X 28	88.2	Surface Mounted Channel c/w Aluminium Reflector And Louvre
12	SSV 228 (1X4)	2 X 28	88.6	Surface Mounted Channel c/w Aluminium Reflector And Louvre
13	SRV 228	2 X 28	88.2	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
14	SRV 228 (1X4)	2 X 28	88.6	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
15	SWV 228	2 X 28	88.2	Recessed Mounted Channel c/w Aluminium Reflector And Louvre
16	SSV 328	3 X 28	90.0	Surface Mounted Channel c/w Aluminium Reflector And Louvre
17	SRV 328	3 X 28	90.0	Recessed Mounted Channel c/w Aluminium Reflector And Louvre
18	SWV 328	3 X 28	90.0	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre



LAMPIRAN

Perihal Barangan : FLUORESCENT LUMINAIRES (T5)

Nama Syarikat : SIRIJAYA INDUSTRIES SDN. BHD.

Alamat Syarikat : NO. 9, LEBUH PERUSAHAAN KLEBANG 9, IGB INTERNATIONAL INDUSTRIAL PARK,
31200 CHEMOR, PERAK DARUL RIDZUAN

No. Tel : 05 - 292 3888

No. Fax : 05 - 291 2222

Email : qa@sirijaya.com

Nama Pengilang : SIRIJAYA INDUSTRIES SDN. BHD.

Negara Pengilang : MALAYSIA

Jenama : SJ LITE

No. Perakuan ST/ No. Sijil/ Laporan Ujian Jenis : PERAKUAN ST : SJT161312186392022, SJT161307107342023, SJT161307115272023,
SJT161307115332023, SJT161307117182023, SJT161307117342023, SJT161308119712023,
SJT161308135822023, SJT161308135832023, SJT161308135842023, SJT161308126502023 &
SJT161311189832023
: PENSIJILAN SIRIM : PS008202 & PS008206
: LAPORAN UJIAN SIRIM : 2021PB0008, 2021PB0008-A1, 2021PB0009, 2021PB0009-A1, 2021PB0103,
2021PB0103-A1, 2022PB0093, 2022PB0104, 2022PB0105, 2022PB0107, 2022PB0108, 2022PB0109,
2022PB0110, 2022PB0111 & 2022PB0112
LAPORAN UJIAN LIGHTLAB : LL18693

Tarikh Tamat : 15.06.2026

Rujukan Standard : MS IEC 60598-1:2012, MS IEC 60598-2-1:1997, MS IEC 60598-2-2:1998 & CIE 121-1996

Catatan : i) REFLECTOR : MIRO 4
ii) ELECTRONIC BALLAST : SJLITE - AES 1X14-35 IP & AES 2X14-28 IP
PHILIPS - HF-S 114-35 TL5 II & HF-S 214-28 TL5 II
OSRAM - QT-FIT5 1X14-35 & QT-FIT5 2X14-35
iii) LAMP HOLDER : SIRIJAYA - S532, S533, S960, S961, S910 & S911

Muka surat : 3 daripada 3

KETERANGAN

BIL	MODEL	KADARAN WATT (W)	LIGHT OUTPUT RATIO (%)	JENIS
19	SSV 428	4 X 28	87.0	Surface Mounted Channel c/w Aluminium Reflector And Louvre
20	SRV 428	4 X 28	87.0	Recessed Mounted Channel (Tee Bar Ceiling Grid) c/w Aluminium Reflector And Louvre
21	SWV 428	4 X 28	87.0	Recessed Mounted Channel c/w Aluminium Reflector And Louvre

